

## **Purchasing Department**

140 Stonewall Avenue West, Ste 204 Fayetteville, GA 30214 Phone: 770-305-5420 www.fayettecountyga.gov

October 12, 2022

Subject: Request for Quotes #2173-A: Roof Repair @ 3 County Locations

Addendum #1

Gentlemen/Ladies:

Below, please find responses to questions, clarification, or additional information for the above referenced Request for Quotes (RFQ). You will need to consider this information when preparing your quote.

## **Senior Center**

1. The Senior Center shows four (4) sections on the building, but only two sections have details. Are there any details for section 2 and section 3?

Section 2 the dome wood needs to be replace all upper and middle sections and any other place found that's bad.

2. Are there any active interior leaks?

No

3. Can a second look be approved for a later day?

Unfortunately, we will not be able to provide a second visit to the Senior Center.

4. Will there be any replacements to the shingle roof?

No

5. Are there quantities built in or will it be the contractor's discretion on what boards and shingles to replace?

This will be the contractor's discretion.

6. Is there an order of repair for the three buildings or sections within the buildings?

No, however the contractor shall complete each section before moving to the next.

7. Is the interior work part of the project?

No. The county will make the necessary repairs inside of the building.

8. Should the quote include replacing of the metal panel?

Only metal flashing is to be replace.

9. Once the wood is redone do you want the flashing tilted when replaced?

10. Please clarify the section of the TPO to replace.

The raise vent hood area.

## **Sherriff Office**

- 11. How would you like the contractor to quote for the blisters?

  There are approximately 350 linear feet of blister areas. Assume this quantity for your quote.
- 12. Can a second look be approved for a later in the day, to verify the number of blisters?

  A second look can be scheduled for Friday, October 14, 2022 at 1:00 p.m. Please contact Larry Mitchell at (770) 320-6004 or <a href="mailto:lmitchell@fayettecountyga.gov">lmitchell@fayettecountyga.gov</a> to confirm that you will be there.
- 13. Training Center
- 14. Is the county requiring the boot to be painted to match the current color? Yes
- 15. Upon field inspection of all the restroom, section 2, all fasteners are corroded. All fasteners to be replaced?

Yes, all fasteners are to be replaced. There are approximately 500 fasteners.

Received by (Name):	Company	

Note: If this addendum is not returned to the Fayette County Purchasing Department or if it is returned not signed, responding individuals, companies or other organizations will still be responsible for the requirements of this addendum and the specifications or changes herein.

The opening date for this RFQ is hereby changed. The new opening time and date are 3:00 p.m. on Thursday, October 20, 2022. Quotes must be received by the Purchasing Department at the address above, Suite 204, at or before the opening date and time.

The time for questions regarding this solicitation has passed. We will not be able to respond to any additional inquiries about this project.

If you have questions, please contact Sherry White, Contract Administrator at (770) 305-5314 fax (770) 719-5544 or email at swhite@fayettecountyga.gov.

Sincerely,

Ted L. Burgess

Director of Purchasing